


REV	REVISION DATE	RELEASE NUMBER	DESCRIPTION	DRAWN BY	CHECKED BY	APPROVED BY
00	3-24-99	2185	CHANGED DILL NOS. ADDED FARGO NOS; RE-RELEASED .53 WAS "C" DIM.	SJB	JCB	REF
01	8-17-00	2388	ADDED 2 POS.#BB-2U39	SJB	JCB	REF
02	2-12-01	2534	ADDED ALL NUMBERS FOR PLATED COPPER WITH PLATED TERMINAL ADDED UNIVERSAL NO'S.	SJB	JCB	REF
03	5-21-07	4634	ADDED NOTE FOR #BB-3U39'S	SJB	JCB	REF

NOTES:

- 1- I.D. OF ROLLED SECTION TO ACCEPT 10-8 GAGE WIRE. RECOMMENDED WIRE STRIP 22/32".
- 2- UNPLATED COPPER MAT'L.: CA-110. E.T.P. COPPER. FARGO #XX-BBS1.33
- 3- PLATED COPPER MAT'L.: CA-110. E.T.P. TIN PLATED COPPER. .00002-.00008 THICK FARGO #XX-BBS1.33T
- 4- UNPLATED TERMINAL: BRASS CA260. WITH STAINLESS STEEL CONTACT REINFORCING SPRING. FARGO #TF-13PC1UC
- 6- TERMINALS ARE CRIMPED AND SOLDERED.
- 7- SEE DRAWING 171-00-23 FOR CRIMPING AND SOLDERING SPECIFICATIONS.
- 8- PLATED TERMINAL: SILVER PLATED CA195. WITH STAINLESS STEEL CONTACT REINFORCING SPRING. FARGO #TF-13PC1SC



LEFT HAND WIRE STOP
 THIS WIRE STOP ALSO FOR
 BB-3U39.BB-3U39T AND BB-3U39S

FOR UNIVERSAL POSITION

2 POS.	BB-2U39 NO WIRE STOP HOLE		BB-2U39T NO WIRE STOP HOLE		BB-2U39S NO WIRE STOP HOLE		Ø75642 BB-SLV015	.67
7 POS.	Ø92763 BB-7L39	Ø92781 BB-7U39	Ø92787 BB-7L39T	Ø92782 BB-7U39T	BB-7L39S	BB-7U39S	Ø75575 BB-SLV030	2.62
6 POS.	Ø92767 BB-6L39	Ø92780 BB-6U39	Ø92788 BB-6L39T	Ø92783 BB-6U39T	BB-6L39S	BB-6U39S	Ø75640 BB-SLV027	2.23
5 POS.	Ø92764 BB5L39	Ø92779 BB-5U39	Ø92789 BB-5L39T	Ø92784 BB-5U39T	BB-5L39S	BB-5U39S	Ø75570 BB-SLV022	1.84
4 POS.	Ø92768 BB-4L39	Ø92778 BB-4U39	Ø92790 BB-4L39T	Ø92785 BB-4U39T	BB-4L39S	BB-4U39S	Ø75648 BB-SLV017	1.45
3 POS.	Ø92769 BB-3L39	Ø92777 BB-3U39	Ø92791 BB-3L39T	Ø92786 BB-3U39T	BB-3L39S	BB-3U39S	Ø75642 BB-SLV015	1.06
	LEFT CRIMP DILL NO. FARGO NO.	UNIVERSAL DILL NO. FARGO NO.	LEFT CRIMP DILL NO. FARGO NO.	UNIVERSAL DILL NO. FARGO NO.	LEFT CRIMP DILL NO. FARGO NO.	UNIVERSAL DILL NO. FARGO NO.	INSULATOR NO. DILL NO. FARGO NO.	DIM. "A"
	UNPLATED COPPER UNPLATED TERMINAL		PLATED COPPER UNPLATED TERMINAL		PLATED COPPER PLATED TERMINAL			

FILE # 000414-2	SHEET 1 OF 1	FARGO ASSEMBLY OF PA
UNLESS STATED OTHERWISE: DIMENSIONS ARE IN INCHES. AND TOLERANCE ARE:	THIRD ANGLE PROJECTION	P.O. BOX 550 NORRISTOWN, PA 19404 PHONE: 610-272-6850 FAX: 610-272-6858
.X +/- .030		OUR COMPANY GOALS 1. QUALITY 2. DELIVERY 3. FAIR PRICE 4. GOLDEN RULE
.XX +/- .020	DRAWN PHB 3-23-93	ELECTRICAL SYSTEMS ASSEMBLY AND DESIGN
.XXX +/- .010	CHECKED SJB 3-93	TITLE: .390 CENTERLINE BUS BAR, WITH AUTOFUSE TERMINAL AND SPRING CLIP
FRACTIONAL +/- 1/64	APPROVED DATE	DRAWING NUMBER C-171-03-00
ANGULAR +/- 30 MIN	SCALE: NONE	REVISION 03
THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTEREST OF FARGO ASSEMBLY OF PA, INC.		